

SSC Construction Inspection Safety findings

March, 2009

Prepared/presented by:
Daryl Kosturock, Safety Inspector
John Rhodes, Safety Inspector
Bastion Technologies

Contact Info:

Buddy Newbold

buddy.newbold-1@nasa.gov

228-688-3152 phone

288-688-3701 fax

Daryl Kosturock

daryl.kosturock-1@nasa.gov

228-688-3641 phone

228-688-3701 fax

John Rhodes

john.d.rhodes-1@nasa.gov

228-688-2462 phone

228-688-3701 fax

<http://constructionsafety.ssc.nasa.gov/>

Construction Safety Findings: 27 February - 05 March 2009

■ Findings Total: 1

- Serious Findings: 0

- Less than Serious Findings: 1

- A worker was standing in a large dust cloud while dry-cutting concrete, without means of protection from the health hazard.
29 CFR 1926.55

Mishaps / Close Calls: 0

Construction Safety Findings: 06-12 March 2009

- **Findings Total: 0**
 - **Serious Findings: 0**
 - **Less than Serious Findings: 0**

Mishaps / Close Calls: 0

Construction Safety Findings: 13-19 March 2009

■ Findings Total: 1

- Serious Findings: 0

- Less than Serious Findings: 1

■ Lifting Devices: 1

- Contractor was using lifting devices that were not properly labeled and/or tagged. SWI 8834-0001

Mishaps / Close Calls: 1

■ Mishap: 1

- An employee backed a government vehicle into one of the contractor's company vehicles that was parked and unoccupied. Minor damage to the government vehicle, no damage to the contractor's vehicle.

Construction Safety Findings: 20-26 March 2009

- **Findings Total: 1**

- **Serious Findings: 0**

- **Less than Serious Findings: 1**

- **Lifting Devices: 1**

- Contractor was using a synthetic sling as a lifting device that was not rated for lifting. 29 CFR 1926.251

Mishaps / Close Calls: 0

Construction Safety Findings: 27-31 March 2009

- **Findings Total: 1**

- **Serious Findings: 0**

- **Less than Serious Findings: 1**

- PPE: 1

- Several employees not wearing eye protection during a large concrete pour. 29 CFR 1926.102


Mishaps / Close Calls: 0

Summary

- **Total Findings: 4**
- **Serious Findings: 0**
- **Less than serious Findings: 4**
- **Close Calls: 0**
- **Mishaps: 1**
- **Injuries: 0**

2009

Construction Safety Findings by category:




- Fall Protection
- Electrical
- Trenching
- PPE
- Housekeeping
- Ladders
- Other

2009

Total Construction Safety Findings by month


Total: **12**




Hazard Recognition

- The following video demonstrates how some people fail to recognize the hazard prior to a problem.

Let's rely on hazard prevention
instead of luck!





Before you do it, take time to think through it.
Use an AHA.

