

SSC Construction Inspection Safety findings

August, 2008

Prepared/presented by:
Daryl Kosturock, Safety Inspector
Bastion Technologies

Contact Info:

Buddy Newbold

buddy.newbold-1@nasa.gov

228-688-3152 phone

288-688-3701 fax

Daryl Kosturock

daryl.kosturock-1@nasa.gov

228-688-3641 phone

228-688-3701 fax

<http://constructionsafety.ssc.nasa.gov/>

Construction Safety Findings: 01 – 07 August 2008

■ Findings Total: 2

- Serious Findings: 1

■ Fall Protection: 1

- Worker exposed to approximately a fifteen foot fall without using any fall protection. 1926.501

- Less than Serious Findings: 1

■ Fall Protection: 1

- Employee working from an articulating boom lift with the leg straps of his harness not secured. 29 CFR 1925.502

■ Mishaps: 0 / Close Calls: 0

Construction Safety Findings: 08 – 14 August 2008

- **Findings Total: 0**

- Serious Findings: 0

- Less than Serious Findings: 0

- **Mishaps: 0 / Close Calls: 1**

- Close Call: 1

- A worker was attempting to remove debris that was stuck inside a trash chute when another worker began to throw more debris into the chute, nearly hitting the worker that was in the chute.

Construction Safety Findings: 15 – 21 August 2008

■ Findings Total: 3

- Serious Findings: 3

■ Ladders: 3

- Two different workers standing on closed A-frame ladders that were leaning against tent posts. 29 CFR 1926.1053(a)(8)
- Workers using an A-frame ladder for access / egress to a trailer roof. The ladder did not reach or extend three feet above the roof. 29 CFR 1926.1053(b)(1)
- Worker standing on top of an eight foot A-frame ladder with his right foot on the top rung and his left foot the cross bracing. 29 CFR 1926.1053(b)(13)&(14)

- Less than Serious Findings: 0

■ Mishaps: 0 / Close Calls: 0

Construction Safety Findings: 22 – 28 August 2008

- **Findings Total: 1**

- **Serious Findings: 1**

- **Electrical: 1**

- Two different extension cords in use, with damage, plugged into the same panel. 29 CFR 1926.405

- **Less than Serious Findings: 0**

- **Mishaps: 0 / Close Calls: 0**




Summary

- Total Findings: 6
- Serious Findings: 5
- Less than serious Findings: 1
- Close Calls: 1
- Mishaps: 0
- Injuries: 0

2008


Construction Safety Findings by category:



- Fall Protection
- Electrical
- Trenching
- PPE
- Housekeeping
- Ladders
- Other

2008

Total Construction Safety Findings each month



Ladder Safety

- The following is a demonstration of why ladder safety is important, regardless of who you are and what you are doing!

V-17183
Telesteps
12½' Aluminum
Telescoping
Ladder

RETAIL VALUE
\$299.00

QVC PRICE
~~\$242.00~~


INTRODUCTORY
PRICE
\$219.96

S&H \$12.47

TESTIMONIAL LINE: 1-800-395-1601

QVC 1-800-345-1515
www.QVC.com

around the
house



* Safety is a continuing journey,
not a final destination.

